

**South Dakota One Call Notification Board**  
**PO Box 187**  
**Rapid City, SD 57709**

IMPORTANT: This form is provided only as assistance in preparing responses to South Dakota One Call Complaints. Although it is not required, we encourage you to use this form. Please be as thorough as possible to assist the Enforcement Panel in making its determination.

<b>COMPLAINT DOCKET NUMBER:</b>	OC20-072
<b>Reply filed on behalf of (company name):</b>	Wild West Construction L.L.C.
<b>Contact Person:</b>	Mike Grose
<b>Phone</b>	(307) 262-4157
<b>Name or Company Name:</b>	Wild West Construction L.L.C.
<b>Street Address or PO Box</b>	91-55 ranch road Glenrock, Wyoming 82637 United States
<b>Email</b>	<a href="mailto:mgoilfield@yahoo.com">mgoilfield@yahoo.com</a>
<b>Date</b>	Oct 26, 2020
<b>Were you previously aware of these allegations?</b>	Yes
<b>Provide detail including whom you spoke with:</b>	Info was provided by e-mail
<b>Do you believe the statutes listed (if any) by the complainant were violated?</b>	No
<b>Why or why not?</b>	To all of our understand all of the regulations were followed
<b>Do you dispute the alleged violation of SD One Call statute or rule occurred?</b>	No
<b>Do you dispute the complainant's statements regarding the intentional or unintentional nature of the alleged violation?</b>	No

**Was a locate requested from SD One Call?** Yes

**If yes, please provide the ticket number and a copy of the locate ticket**  
locate was called in by property owner by request of the contractor, Bruce Knell was acting as the contractor representative cause he had eyes on the project that need to be done and was in the state as we were not

**Locate ticket #** 2026003430

**Start date on ticket:** Sep 18, 2020

**Start time on ticket:** 10:00 AM

**Did excavation begin before the start date / time on the ticket?** No

**Was a minimum horizontal clearance of 18 inches maintained between a marked facility and mechanical equipment?** Yes

**Were buried facilities exposed by hand or non-invasive equipment prior to excavation?** Yes

**Were facilities marked?** Yes

**Was the marking complete prior to the start time on the ticket?** Yes

**Was the excavation site pre-marked with white paint?** NA

**Was the facility marked accurately (within 18 inches)?** Yes

**Was there reasonable care to maintain locate marks for the life of project?** Yes

**Did the complainant correctly describe the type of facility involved?** Yes

**Provide detail:**

Yes they did this was at 317 Gold Street in Lead South Dakota involving a 1/2 inch gas line

**Did the complainant correctly describe the damages that resulted from the alleged violation?**

Yes

**Provide detail:**

Yes they did the damages had happened after the line was exposed by hand at the house meter at 19" deep

**Was the one-call notification center immediately notified of the damage, dislocation, or disturbance?**

Yes

**Was the operator of the facility immediately notified of the damage, dislocation, or disturbance?**

Yes

**Was there an escape of any flammable, toxic, or corrosive gas or liquid?**

Yes and 911 was contacted by an Excavator

**Did the complainant correctly describe the damages that resulted from the alleged violation?**

Yes

**Were damages on public right of way or private property?**

Private

**Did complainant correctly describe how operator service was affected?**

Yes

**Provide detail:**

Yes the site was down for 2 hours, line was pinched off 5 min. after the line was damaged by the contractor

**Was anyone injured as a result of facility damage?**

No

**Were there fatalities?**

No

**Describe your plans and procedures to ensure compliance with SD One Call statutes and rules:**

Our plans to ensure compliance with SD One Call is to be present when lines are located on property as to find out Depth of the lines that located as well as to answer any questions that we may have

---

**Has a complaint been filed against you in the past for SD One Call violations?** No

**Please provide any additional information to support your position:**

locate was called in by property owner by request of the contractor, Bruce Knell was acting as the contractor representative cause he had eyes on the project that need to be done and was in the state as we were not. In the report it states the 911 was not called, but they were the Lead police department Sargent had showed up and had blocked off the street with his car as well as police tape at the top of the hill cause it was a one way, after he had showed up 4 of the Lead fire department members had as well. The police officer had taken pictures of the exposed line that was only at 3 inches deep, the line was dug in at 18 inches deep and then was rerouted up to the 3 inches in depth to go over and old water line that was not in use, and then back to the 18 inches in depth. The SD One Call, 911 and the gas Company were all notified. After the Gas Company had showed up they had told the police and the fire departments that they were no longer needed.

---

**Attachment Information**

File names should not include symbols. Example:( \$, &, \*, % ) etc.

---